

Bangladesh Jute Energy Assessment - Plant Report Card

V1-2012

Sample Jute Report Card (Confidential Plant Information Removed)



This report provides a summary of the technical assessment completed for this facility. This includes the purchased energy use and cost profiles, a breakdown of energy consuming systems, a score of the technical best practices implemented, and useful links to Energy programs and benchmarking information.

Survey completed by: Marc-André Comeau
Date:


Report of Purchased Energy

The charts below represent the purchased energy for your facility. The quantity of energy purchased has been converted to a common unit (GJ) to allow comparison between fuels.

Annual Purchased Energy Cost [BDT], 2011	17,698,959.80	Annual Net Purchased Energy [GJ], 2011	11,519.03
--	---------------	--	-----------




This chart shows energy use by end use as a percent of total purchased energy.



Scope of Energy Intensity	Main Product [units]	Calculated energy intensity (fuel per total unit of product) [GJ/unit]
Includes process and comfort energy ¹	Total: Sack and Twine [tonnes]	0.3

¹Comfort energy includes energy used for heating, ventilation, air conditioning and lighting



Bangladesh Industrial Energy Assessment and Management Study - Opportunities Identification

 Press here to
 sort opportunities

 Warning: any data entered in
 column B of this tab will be erased

Technical Energy Management Opportunities

 The following table prioritizes energy savings opportunities³ (high, medium and low energy savings potential in each area) in your facility, in terms of your current energy use and implementation of best practices. The opportunities listed include their approximate annual savings for each end use.

 The largest area of opportunity for energy savings in this facility is: **Fans, Motors, Pumps**

Jute production	Maximum potential Savings⁷	Energy Savings⁷	GHG⁶	Maximum Potential Energy Cost Savings⁷	Measure Lib Tab No.	Relative Implementation Difficulty	Relative Implementation Cost
High Priority End-use	[%]	[GJ]	[ton]	[BDT]			
Self lubricating bushes, runners & other components: Save up to 5% of energy use.	5.00%	389	22	590,851	J-8	Low	Low
Modification in Jute Spreader or softener machine: Save up to 5% of jute softning process electrical energy use.	5.00%	8	0	12,588	J-6	Medium	Medium
Modification of weaving machines: Save up to 5% of weaving electrical energy use.	5.00%	22	1	33,569	J-10	Medium	Medium
Replacement of Bailing Press Pump with Hydraulic Oil Power Pack: save up to 10% of bailing pump electrical energy use.	10.00%	2	0	3,788	J-3	Medium	Medium
Change of belts in drawing ,weaving and carding section to reduce slippage and better utilization of power: Save up to 5% of Jute drawing, carding, and weaving process electrical energy use.	5.00%	80	4	121,337	J-5	Medium	Medium
Modification of roll and cop winding machine: Save 10 -15% of Jute winding electrical energy use.	15.00%	155	9	236,030	J-11	Medium	Medium
Replacement of old conventional card machines with new high productivity energy efficient card machines: Save up to 10% of Jute carding process electrical energy use.	10.00%	74	4	111,896	J-4	High	High
System Practice - Electricity	Maximum potential Savings⁷	Energy Savings⁷	GHG⁶	Maximum Potential Energy Cost Savings⁷			
High Priority End-use	[%]	[GJ]	[ton]	[BDT]			
Sub-metering and interval metering: save up to 5% for all fuel sources	5.0%	293	93	692,989	1	Medium	Medium
HE dry-type transformers: save 1% in electrical energy use	1.0%	59	19	138,598	3	High	High
Lighting	Maximum potential Savings⁷	Energy Savings⁷	GHG⁶	Maximum Potential Energy Cost Savings⁷			
Medium Priority End-use	[%]	[GJ]	[ton]	[BDT]			
Use of electronic ballasts saving 20-30% of lighting energy use	30.0%	344	72	541,809	29	Low	Low
Lighting controls: occupancy sensors: savings of 15% of lighting energy use	15.0%	172	36	270,905	125	Low	Low
Efficient lighting design: savings of 15% of lighting energy use	15.0%	172	36	270,905	109	Low	Low
High efficiency lights fixtures: savings of 20 - 75% of lighting energy use	75.0%	860	181	1,354,523	108	Low	Low
Lighting controls: on/off timers: savings of 15% of lighting energy use	15.0%	172	36	270,905	110	Medium	Medium
Ovens / Dryers / Kilns / Furnaces	Maximum potential Savings⁷	Energy Savings⁷	GHG⁶	Maximum Potential Energy Cost Savings⁷			
Medium Priority End-use	[%]	[GJ]	[ton]	[BDT]			
Exhaust gas heat recovery: savings of 15% of energy use	15.0%	72	5	46,677	24,36,44,51	Medium	Medium
High efficiency burner: 10% savings in energy use	10.0%	48	3	31,118	22,34,42,48	Medium	Medium
Control air-fuel ratio through flue gas monitoring: 2 to 15% savings in energy use	15.0%	72	5	46,677	120,121,122,123	Medium	Medium
Advanced heating and process control: savings of 10% of energy use	10.0%	48	3	31,118	26,38,46,53	Medium	Medium
Insulation: savings of 5% of energy use	5.0%	24	2	15,559	25,37,45,52	Medium	Medium
Air curtains: savings of 15% of heating energy use	15.0%	72	5	46,677	23,50	Low	Medium
Fans, Motors, Pumps	Maximum potential Savings⁷	Energy Savings⁷	GHG⁶	Maximum Potential Energy Cost Savings⁷			
High Priority End-use	[%]	[GJ]	[ton]	[BDT]			
Impeller trimming: save up to 15% in pump energy use	15.0%	36	8	57,048	69	Low	Low
Fan impeller trimming or inlet guide vanes: save 15% in fan energy use	15.0%	36	8	57,048	74	Low	Low
Optimized motor control: savings of 5% of motor energy use	5.0%	401	3	19,016	81	Low	Low
Preventative maintenance: savings of 5% of motive-power energy use	5.0%	401	3	19,016	72,78,83	Low	Low
High/premium efficiency motors for pumps: motor energy savings of 0.8 to 8%	8.0%	19	4	30,425	68	Low	Medium
High/premium efficiency motors for fans: motor energy savings of 2%	2.0%	5	1	7,606	73	Low	Medium
High/premium efficiency motors for equipment: motor energy savings of 2%	2.0%	160	1	7,606	79	Low	Medium
Correctly sized motors: savings of 2% of motor energy use	2.0%	160	1	7,606	80	Medium	Medium
Premium efficiency control with ASDs: save 20% in pumping energy use	20.0%	48	10	76,064	71	Medium	Medium
Synchronous belts: savings of 2% of motor energy use	2.0%	5	1	7,606	141	Medium	Medium
Premium efficiency control with ASD: save 20% in fan energy use	20.0%	48	10	76,064	76	Medium	Medium
Premium efficiency control with ASDs: save 20% in motor energy use	20.0%	1603	10	76,064	35	Medium	Medium
HVAC and Air System	Maximum potential Savings⁷	Energy Savings⁷	GHG⁶	Maximum Potential Energy Cost Savings⁷			
Medium Priority End-use	[%]	[GJ]	[ton]	[BDT]			
High efficiency non-packaged HVAC: savings of 25% of indirect heating energy use	25.0%	67	28	211,727	98	Medium	Medium

The potential savings presented are an estimate of **maximum** savings per individual opportunity and are not additive. Interactive effects will reduce the total potential savings if more than one opportunity is implemented.

General practices for implementation of energy efficiency opportunities:

- a) Sequence of implementation i) Optimize the demand and output of equipment as a first step (eg. fix air leaks) ii) Properly size the supply equipment and, if possible, upgrade to more efficient equipment, at the same time.
- b) If the equipment demand is low, then consider optimization of the equipment characteristics, such as efficiency. If demand is fluctuating, consider implementing measures to meet the fluctuating demand, such as variable speed drives or other controls.
- c) When implementing control equipment to optimize energy use (such as VSDs or advanced control), consider the effects on the power factor of the facility.

Notes

5. The opportunities are based on both the energy consumed and the technical best practices for your facility. Please note that the values shown are approximations and are based on site specific conditions.
6. Greenhouse Gases (GHGs) factors are based on The Guidelines for Measurement, Reporting and Verification of GHG Emission Reductions in JBIC's GREEN (the "J-MRV Guidelines"). June 2010. Japan Bank for International Cooperation
7. Energy savings are maximum values based on all energy consumed by each grouped end use and does not consider equipment that is already efficient. More detailed analysis is required to determine precise energy and cost savings.
8. For compressors using steam derived from natural gas driven processes, the steam energy use is not corrected by a service factor. Savings for natural gas derived steam is based on natural gas costs.